

# Australia and New Zealand Certificate of Suitability

**Certificate**  
ULL-103860

**Issue date**  
2025-04-30

**Expiration date**  
2030-04-30



[www.jasanz.org/register](http://www.jasanz.org/register)

This is to acknowledge that

**Signify Netherlands B.V.**

High Tech Campus 48, EINDHOVEN 5656 AE  
Netherlands

has had

**Electronic controlgear for LED modules**

[refer following page(s) for models list]

evaluated and meets the requirements of the standard(s)

**AS/NZS 61347.1:2016+A1; AS  
61347.2.13:2018**

ANZ Certification Scheme requirements.



Jacky Wong (Certification Officer)

Certification Body:  
UL International New Zealand Limited,  
54 Tarndale Grove, Albany, Auckland 0632, New Zealand.

Issued for use in Australia and New Zealand only.  
All dates are in Year-Month-Day format (YYYY-MM-DD).

# Australia and New Zealand

## Certificate of Suitability

**Certificate No:** ULL-103860

**Date of Issue/Revision:** 2025-04-30

**Trade Name or Trademark:** PHILIPS, SIGNIFY

**Risk Class / NSW Declared Class:** EESS OUT OF SCOPE - Non-prescribed / non-declared

**IEC Standard Country Differences:** AU and NZ

**Certification Marking:** The RCM may be applied to the product and all the requirements of all relevant parts of AS/NZS 4417 applicable to the article shall be fulfilled.

**Additional Certification Conditions:** None.

### Model Details:

Model Name
Xi CR 110W 0.2-1.05A SDMP 230V C133 sXt

### Additional Information:

Rating :

U<sub>in</sub>: 220-240 V, f<sub>n</sub>: 50/60 Hz, I<sub>in</sub>: 0.56-0.51 A, P<sub>in</sub>: 123 W, PF: 0.95,

U<sub>output</sub>: 50-220 Vdc, U<sub>out</sub> = 270 V max,

I<sub>rated</sub>: 200-1050 mA, P<sub>rated</sub>: 110 W, t<sub>c</sub>: 80 °C, Built-in